



ENGINEERING SPECIFICATION

SYMCOM MODELS 201-100-SP, 201-200-SP, 201-200-SP-T-9 SINGLE-PHASE VOLTAGE MONITOR/PROTECTION RELAY

PART 1 GENERAL

1.1 REFERENCES

- A. UL 508 Industrial Control Equipment – Underwriters Laboratories
- B. IEC 60947 Low Voltage Switchgear and Controlgear – International Electrotechnical Commission
- C. ANSI/IEEE C62.41 – American National Standards Institute/Institute of Electrical & Electronics Engineers
- D. CSA C22.2 No. 14 Industrial Control Equipment – Canadian Standards Association

1.1 WARRANTY

- A. Manufacturer Warranty: The manufacturer shall guarantee the equipment to be free from material and workmanship defects for a period of five years from the date of manufacture when installed and operated according to the manufacturer's requirements.

PART 2 PRODUCTS

2.1 MANUFACTURERS

For Model 201-100-SP

The equipment specified shall be the Model 201-100-SP, manufactured by SymCom, Inc.

For Model 201-200-SP

The equipment specified shall be the Model 201-200-SP, manufactured by SymCom, Inc.

For Model 201-200-SP-T-9

The equipment specified shall be the Model 201-200-SP-T-9, manufactured by SymCom, Inc.

2.2 DESCRIPTION

- A. Regulatory Requirements:
 1. The equipment shall be UL Listed as type NKCR—Industrial Control Equipment-Motor Controllers-Auxiliary Devices.
 2. The equipment shall be ULC Listed as type NKCR7—Industrial Control Equipment-Motor Controllers-Auxiliary Devices Certified for Canada.
 3. The equipment shall be CE marked for use in the European Union and evaluated against IEC 60947 Low Voltage Switchgear and Controlgear.

2.3 PERFORMANCE/DESIGN CRITERIA: SINGLE-PHASE VOLTAGE MONITOR/PROTECTION RELAY

- A. Protective Relay Functions
 1. The equipment shall provide protection against the following conditions:
 - For All Models*
 - a. low voltage (90% of nominal setting)
 - For the 201-200-SP-T-9 only*
 - b. high voltage (110% of nominal setting)
- B. Capabilities and Features
 1. Inputs
 - For the 201-100-SP only*
 - a. The equipment shall accept single-phase input voltage range of 95-120VAC, adjustable.
 - For the 201-200-SP and 201-200-SP-T-9*
 - a. The equipment shall accept single-phase input voltage range of 190-240VAC, adjustable.
 2. Outputs
 - a. The equipment shall include one Form C output relay contact pilot duty rated 480VA @ 240VAC.
 - b. The equipment shall include one Form C output relay contact general purpose rated 10A @ 240VAC.
 3. Functional Specifications
 - The equipment shall include:
 - 1) low voltage trip 90%
 - 2) low voltage reset 93%
 - 3) a trip delay of 4 seconds
 - 4) a restart delay of 2 seconds
 - 5) voltage accuracy $\pm 1\%$
 - For the 201-200-SP-T-9 only*
 - 6) a high voltage trip 110%
 - 7) high voltage reset 107%
 - b. The equipment shall have an indicator light. The indicator light has the capability to indicate whether the phase monitor is in run mode, restart delay mode, or fault mode.
 - 1) Fault modes shall include:
 - a) low voltage
 - For the 201-200-SP-T-9 only*
 - b) high voltage



C. Electromagnetic Compatibility

1. The equipment shall be immune to electrostatic discharge per IEC 61000-4-2, Level 3, 6kV contact discharge and 8kV air discharge.
2. The equipment shall be immune to electrical fast transient bursts exceeding IEC 61000-4-4, Level 4. Specified limits shall be 4kV.
3. The equipment shall be immune to electrical surges per IEC 61000-4-5, Level 4. Specified limits shall be Level 4, 4kV line-to-line, and Level 4, 4kV line-to-ground.
4. The equipment shall be immune to electrical surges per ANSI/IEEE C62.41 Surge and Ring Wave. Specified limits shall be 6kV line-to-line.
5. The equipment shall be immune to radiated radio frequency emissions. Specified limits shall be 10V/m at 150 MHz.

D. Dielectric Isolation: Equipment withstands an alternating current potential of 1000V plus twice the rated voltage of the equipment for 1 minute without breakdown between uninsulated live parts and the enclosure with the contacts open and closed; between terminals of opposite polarity with the contacts closed; and between uninsulated live parts of different circuits.

E. Environmental Requirements

1. The equipment shall operate continuously without derating in surrounding air temperatures of -40° to 70°C (-40° to 158°F).
2. The equipment shall operate continuously without derating in relative humidity of 10% up to 95% non-condensing per IEC 68-2-3.
3. The equipment shall operate properly after storage in ambient temperatures of -40° to 80°C (-40° to 176°F).

F. Dimensions: The equipment dimensions shall not exceed 1.750" H x 2.375" W x 4.125" D (with socket).

G. Mounting:

1. The equipment shall be mounted using the SymCom OT08-PC 8-pin octal socket.
 - a. The socket shall be 600V rated.
 - b. The socket shall be 10A rated.
 - c. The socket shall provide a means for mounting on the surface or on a DIN rail.

End of Section